

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26884

1. OWNER Joe Sceirine ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P.O. Box 1013 Sceirine Lane Yerington  
Yerington, NV 89447  
 2. LOCATION NE 1/4 NE 1/4 Sec 3 T 13 N 25 E Lyon County  
 PERMIT NO. 51939 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	7	7
Sand & gravel		7	43	36
Blue clay		43	47	4
Gravel/cobbles/boulders		47	115	68
Sand/gravel		115	120	5
Cobbles/gravel/sand		120	128	8
Gravel/cobbles		128	135	7
Sand/gravel/cobbles/boulders		135	178	43
Sand/gravel		178	205	27
Gravel/sand/cobbles		205	218	13
Blue clay		218	231	13
Sand/gravel/cobbles		231	255	24
Brown clay		255	258	3
Sand/gravel		258	265	7
Sand/gravel/boulders		265	325	60
Large boulders		325	342	17
Sand/gravel		342	360	18
Boulders/gravel		360	385	15
Boulders/gravel/clay		385	450	65

94 JUN -8 P 1:50  
 STATE ENGINEER

8. WELL CONSTRUCTION  
 Depth Drilled 450 Feet Depth Cased 440 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 36 Inches 0 Feet To 50 Feet  
28 Inches 50 Feet 450 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
30	12 ga	conductor	+2	50
16	42.05	.250	+2	100

Perforations:  
 Type perforation Mill slot/louvered  
 Size perforation 1/8 X 3  
 From 100-200 feet to louvered full feet  
 From 200-220 feet to mill double feet  
 From 220-260 feet to mill single feet  
 From 260-360 feet to full flow feet  
 From 360-380 feet to mill single feet  
380-440 feet to mill double feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Cement Grout  
 Placement Method:  Pumped  Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 0 feet to 450 feet

9. WATER LEVEL  
 Static water level 35 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Humboldt Drilling & Pump Co., Inc. Contractor  
 Address P.O. Box 590 Contractor  
Winnemucca, NV 89446  
 Nevada contractor's license number issued by the State Contractor's Board 015234  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1562  
 Signed C. C. Gaylor  
 By driller performing actual drilling on site or contractor  
 Date 4-29-94

Date started April 1, 19 94  
 Date completed April 8, 19 94

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>3000</u>	<u>150</u>	<u>8</u>	