

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29311

1. OWNER Leon Garilowitz ADDRESS AT WELL LOCATION 4233 Emerson St Carson City NV 89701
MAILING ADDRESS 4233 Emerson St Carson City NV 89701
2. LOCATION NE 1/4 NE 1/4 Sec 5 T. 15 S. R. 20 E Carson County
PERMIT NO. 08-113-15 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other Mad

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Overburden		0	8	8
Hard Pack Clay		8	23	15
Course DG Sands		23	85	62
Brown Clay w/small Course Sands		85	140	55
Hard Broken Sand and Gravel	XXX	140	160	20

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet
HOLE DIAMETER (BIT SIZE)
From 1 1/4 Inches To 0 Feet 160 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/4</u>	<u>13.03</u>	<u>1.88</u>	<u>0</u>	<u>160</u>

Perforations:
Type perforation M:11 Slot
Size perforation 3 x 3/32
From 140 feet to 160 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow _____ G.P.M. 10 P.S.I.
Water temperature cold °F Quality Good

Date started 4-20 1995
Date completed 4-22 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>10</u>	<u>60</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A.S.H. Pump Company Contractor
Address 6551 Hwy 50 E #3 Carson City NV 89701 Contractor
Nevada contractor's license number 31839 issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources / the on-site driller 1905
Signed Michael J. Haek
By driller performing actual drilling on site or contractor
Date 4-24-95