WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48807
Permit No.
Basin 104

NOTICE OF INTENT NO. 16695

1. OWNER Parlex Corp.
MAILING ADDRESS 3000 Conestoga Drive
Carson City NV

ADDRESS AT WELL LOCATION Same

2. LOCATION NE ¼ SE ¼ Sec. 33 T. 16 N/S R. 20 E. Carson County
PERMIT NO. Old No # 399 Issued by Water Resources
8-814-04 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Sand	NO	0	14	14
Sandy Cobbles	NO	14	16	2
The well was found in good condition. We removed the cavity box, drilled out the casing and pressure grouted the hole from the bottom up using neat cement. The cement was mixed at a ratio of one sack of cement per 5 gallons of water				
Plugging of well under log # 36887				

'94 JUL -8 11:43
STATE ENGINEER'S OFFICE

Date started 11/20, 1993
Date completed 11/20, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

N/A

8. WELL CONSTRUCTION
Depth Drilled 16 Feet Depth Cased 16 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	16 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	Sch. 40	PVC		

Perforations:
Type perforation Factory Slot
Size perforation .020
From feet to feet
From 10 feet to 16 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 7 feet
Placement Method: ☒ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 7 feet to 16 feet

9. WATER LEVEL
Static water level N/A feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ANDRESEN EXPLORATION DRILLING Contractor
Address 1635 BELFORD RD. Contractor
RENO, NV. 89509
Nevada contractor's license number issued by the State Contractor's Board 0034525
Nevada driller's license number issued by the Division of Water Resources the on-site driller N-1667
Signed [signature] By driller performing actual drilling on site or contractor
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627