WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48608
Permit No.
Basin 103

NOTICE OF INTENT NO. 29308

1. OWNER Pete Leonard
MAILING ADDRESS
ADDRESS AT WELL LOCATION Test Hole for Sutro Tunnel Co.

2. LOCATION NW ¼ NW ¼ Sec. 13 T. 16 ☒ S R. 21 E. Lyon County
PERMIT NO. W-427 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other Test

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soft Blow Sands		0	35	35
Coarse DG Sands w/Larger River Rock		35	87	
Brown Clay Seam		87	105	
Large Gravels and Sand Coarse	xxx	105	205	
Bed Rock Hard		205	207	
Drilled Test Hole 205' Set Temporary Plastic Pipe to get Water Sample Pulled Plastic Pipe Out and Pumped Hole Full of Cement Grout and Backfilled				

Date started 4-17, 1995
Date completed 4-20, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
60 +		4 HRS

8. WELL CONSTRUCTION
Depth Drilled 205 Feet Depth Cased 0 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
9 7/8	0	205

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
	N/A			

Perforations:
Type perforation N/A
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal N/A
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From N/A feet to N/A feet

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Company (Contractor)
Address 6551 Hwy 50 E #3 (Contractor)
Carson City NV. 89701
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack (By driller performing actual drilling on site or contractor)
Date 4-22-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627