

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16563

1. OWNER Worth Group Architects ADDRESS AT WELL LOCATION N/A
 MAILING ADDRESS 85 Keystone Ave., Suite B Reno, Nev. 89503

2. LOCATION NW 1/4 SE 1/4 Sec. 28 T 18 R 20 E Washoe County
 PERMIT NO. M/O - 882 017-011-08 N/A Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Clayey sand (sc) w/ gravel</u>		<u>0.0</u>	<u>5.0</u>	<u>5.0</u>
<u>Silty sand (sm)</u>		<u>5.0</u>	<u>10.0</u>	<u>5.0</u>
<u>Clayey sand (sc)</u>		<u>10.0</u>	<u>24.0</u>	<u>14.0</u>
<u>Silty sand (sm)</u>		<u>24.0</u>	<u>33.0</u>	<u>9.0</u>

8. WELL CONSTRUCTION
 Depth Drilled 33.0 Feet Depth Cased 33.0 Feet

HOLE DIAMETER (BIT SIZE)
 From 8.5 Inches To 0.0 Feet 33.0 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>	<u>0.70</u>	<u>0.308</u>	<u>0.0</u>	<u>33.0</u>

Perforations:
 Type perforation slotted screen
 Size perforation 0.020 inch
 From 23.0 feet to 33.0 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 0.0 to 20.0' Neat Cement
 Placement Method: Pumped Bentonite Cement Grout
 Poured 20.0 to 22.0' Concrete Grout

Gravel Packed: Yes No
 From 22.0 feet to 33.0 feet

9. WATER LEVEL
 Static water level 28.5 feet below land surface
 Artesian flow NO G.P.M. N/A P.S.I.
 Water temperature warm °F Quality Murky

Date started 4-25-1995
 Date completed 4-25-1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Dale A. Lehman Contractor
 Address 520 Edison Way Reno, Nevada 89502
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1976
 Signed Dale A. Lehman
 By driller performing actual drilling on site or contractor
 Date 4-26-95