WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 4851
Permit No.
Basin 087

NOTICE OF INTENT NO. 26078

1. OWNER SECURITY PACIFIC PROPERTIES
MAILING ADDRESS
ADDRESS AT WELL LOCATION E. PRATER AND VISTA BLVD., AND LOOP RD. SPARKS, NV.

2. LOCATION NW ¼ SE ¼ Sec. 2 T. 19 N/S R. 20 E. WASHOE County
PERMIT NO. m/o 727 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other AUGER

6. LITHOLOGIC LOG MW-2

Material	Water Strata	From	To	Thickness
ON MAY 13, WE FOUND THE MONITORING WELL IN GOOD CONDITION. WE THEN PROCEEDED TO TAKE THE CAP OFF THE WELL AND DRILL THE CASING OUT TO 25'. WE THEN COMPLETED THE ABANDONMENT BY PRESSURE GROUTING THE HOLE WITH NEAT CEMENT FROM THE BOTTOM TO THE SURFACE.				

Date started 5/13, 1994
Date completed 5/13, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	25 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	40'	PVC	0'	25'

Perforations:
Type perforation FACTORY
Size perforation .020
From 5 feet to 25' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 25'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 18' feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 60.0 °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ANDRESEN EXPLORATION DRILLING (Contractor)
Address 1635 BELFORD RD. (Contractor)
RENO, NV. 89509
Nevada contractor's license number issued by the State Contractor's Board 0034525
Nevada driller's license number issued by the Division of Water Resources 1028 (the on-site driller)
Signed (By driller performing actual drilling on site or contractor)
Date 6/13/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627