WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48854
Permit No.
Basin 087

NOTICE OF INTENT NO. 11884

1. OWNER CB Concrete
MAILING ADDRESS 3025 Mill Street Reno NV
ADDRESS AT WELL LOCATION 3025 Mill Street Reno NV

2. LOCATION NE ¼ NE ¼ Sec. 18 T. 19 N/S R. 20 E/W Washoe County
PERMIT NO. MO 544 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Well was found to be in good condition. We removed Christy Box and pressure grouted well from bottom up. We used approximately 5 bags of portland Type I-II at a ratio of 6 gallons of water per 96 lb. bag of cement				

Date started 6-17-93, 1993
Date completed 6-17-93, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 34.5 Feet Depth Cased 34.5 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	34.5 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	PVC	Sch. 40	0	34.5

Perforations:
Type perforation Factory Slot
Size perforation .020 Inch
From feet to feet
From 20 feet to 34.5 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 18.5 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 18.5 feet to 34.5 feet

9. WATER LEVEL
Static water level 21.85 feet below land surface
Artesian flow NA G.P.M. NA P.S.I.
Water temperature Cold °F Quality NA

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Andrews Exploration Drilling (Contractor)
Address 1635 Bellford Rd. Reno NV (Contractor)
RENO, NV. 89509
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1667
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 6-17-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627