

OFFICE USE ONLY
 Log No. 48865
 Permit No. _____
 Basin 162



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17110

1. OWNER Bill Moore ADDRESS AT WELL LOCATION 2220 Palm
 MAILING ADDRESS _____

2. LOCATION NE 1/4 NE 1/4 Sec. 19 T. 19 S. N/S R. 53 E County _____
 PERMIT NO. 29-452-11 Valley View Acres. Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|----------|--------------|------|-----|-----------|
| Clay | | 0 | 4 | 4' |
| Caliche | | 4 | 7 | 3' |
| Clay | | 7 | 11 | 4' |
| Caliche | | 11 | 13 | 2' |
| Clay | | 13 | 23 | 10' |
| Caliche | | 23 | 26 | 3' |
| Clay | | 26 | 39 | 13' |
| Caliche | | 39 | 43 | 4' |
| Clay | | 43 | 50 | 7' |
| Caliche | W.B. | 50 | 54 | 4' |
| Clay | | 54 | 68 | 14' |
| Caliche | W.B. | 68 | 70 | 2' |
| Clay | | 70 | 77 | 7' |
| Caliche | W.B. | 77 | 79 | 2' |
| Clay | | 79 | 88 | 9' |
| Caliche | W.B. | 88 | 91 | 3' |
| Clay | | 91 | 97 | 6' |
| Caliche | W.B. | 97 | 99 | 2' |
| Clay | | 99 | 100 | 1' |

8. WELL CONSTRUCTION
 Depth Drilled 100' Feet Depth Cased 100' Feet

HOLE DIAMETER (BIT SIZE)
 From 12 1/2 Inches To 0 Feet 100 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 5/8</u> | <u>16.94</u> | <u>.188</u> | <u>0</u> | <u>100</u> |

Perforations:
 Type perforation Factory Sawcut
 Size perforation 1/8" x 3"
 From 80 feet to 100 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 50 feet to 100 feet

9. WATER LEVEL
 Static water level 96 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address HR 78 box 80358 Contractor
Pahrump NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas Pa
 By driller performing actual drilling on site or contractor
 Date 10/16/95

Date started 10-2 1995
 Date completed 10-5 1995

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|--------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

