WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. SEE BELOW
Permit No.
Basin 064

NOTICE OF INTENT NO. 15265

1. OWNER NDOT
MAILING ADDRESS
ADDRESS AT WELL LOCATION NDOT Maint. Yard sec. of 4th & Galena, Battle Mtn. NV.

2. LOCATION SW ¼ NW ¼ Sec. 20 T. 32 N/S R. 45 E. Lander County
PERMIT NO. m/o-272-A (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
The well was found to be in good condition. We removed the rusty box. The casing was drilled out. Then we mixed grout at a ratio of 6 gal. water per sack of cement and pressure grouted the boring from the bottom up, using approx. 25 gal. of grout. We then let the grout settle and topped off the boring.				
MW 1, MW 2, MW 3, MW 4, MW 5				
MW 6, MW 7				
	LOG #			
	48882	MW1		
	48883	MW2		
	48884	MW3		
	48885	MW4		
	48886	MW5		
	48887	MW6		
	48888	MW7		

STATE ENGINEER'S OFFICE 93 JUL -8 P1:43

Date started 7-19, 1993
Date completed, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 19 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	20 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4			0	19.0

Perforations:
Type perforation slotted
Size perforation 0.020
From 4 1/2 feet to 19 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 20
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 6 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature cold °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ANDRESEN EXPLORATION DRILLING (Contractor)
Address 1635 Belford Rd. (Contractor)
Reno, NV. 89509
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1667
Signed (By driller performing actual drilling on site or contractor)
Date 6/13/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627