

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO: 15265

1. OWNER N.D.O.T ADDRESS AT WELL LOCATION N.D.O.T. Maint. Yard
 MAILING ADDRESS _____ Sec 25 4th Galena Battle Mtn. NV.

2. LOCATION SW 1/4 NW 1/4 Sec 20 T 32 QRS R 45 E Lander County

PERMIT NO. 16-272-A Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
The well was found to be in good condition. We removed the Christy box. The casing was drilled out. Then we mixed grout at a ratio of 5 gal. water per sack of cement and pressure grouted the boring from the bottom up, using approx. 25 gal. of grout. We then let the grout settle and topped off the boring.				
<u>MW 1, MW 2, MW 3, MW 4, MW 5</u>				
<u>MW 6, MW 7</u>				
<u>LOG #</u>				
<u>48882 MW1</u>				
<u>48883 MW2</u>				
<u>48884 MW3</u>				
<u>48885 MW4</u>				
<u>48886 MW5</u>				
<u>48887 MW6</u>				
<u>48888 MW7</u>				

JUL -8 P1:43
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 20 Feet Depth Cased 19 Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 Inches _____ Feet 20 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>			<u>0</u>	<u>19.0</u>

Perforations:
 Type perforation slotted
 Size perforation 0.020
 From 1 1/2 feet to 19 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 20 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 20 feet to 19 feet

9. WATER LEVEL
 Static water level 6 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature 60 °F Quality N/A

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ANDRESEN EXPLORATION DRILLING
 Contractor
 Address 1635 Belford Rd.
 Contractor
Reno, NV. 89509
 Nevada contractor's license number issued by the State Contractor's Board 34525
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 10667
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 6/13/94

Date started 4-19, 1993
 Date completed _____, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>N/A</u>		