

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25741

1. OWNER Round Mountain Gold Corp ADDRESS AT WELL LOCATION .....  
 MAILING ADDRESS P.O. Box 480 .....  
Round Mountain, N.V. 89045 MINE SITE

2. LOCATION SW 1/4 SW 1/4 Sec. 19 T. 10 N. R. 44 E Nye County  
 PERMIT NO. M.O. 949  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Alluvium/gravel		0	655	
Clay		655	660	
Gravel + sdy clay		660	705	
Clay		705	710	
Sdy + gravel		710	725	
Clay		725	750	

8. WELL CONSTRUCTION  
 Depth Drilled 750 Feet Depth Cased 750 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10 7/8 Inches 0 Feet 50 Feet  
8 3/4 Inches 50 Feet 320 Feet  
5 7/8 Inches 320 Feet 750 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.81</u>	<u>.188</u>	<u>+1</u>	<u>320</u>
<u>2"</u>	<u>sch. 40</u>		<u>+2</u>	<u>750</u>

Perforations:  
 Type perforation milled  
 Size perforation 48 x 3  
 From 710 feet to 750 feet  
 From ..... feet to ..... feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From ..... feet to ..... feet

9. WATER LEVEL  
 Static water level 530 feet below land surface  
 Artesian flow 20 G.P.M. P.S.I.  
 Water temperature W °F Quality Fair

Date started 8-2, 1995  
 Date completed 8-6, 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	<u>N/A</u>	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Waytek Drilling Contractor  
 Address 2220 Stowe Dr. Contractor  
Reno NV 89511

Nevada contractor's license number issued by the State Contractor's Board 024521  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442

Signed Les Waytek  
 By driller performing actual drilling on site or contractor  
 Date 8-10-95

RECEIVED  
 95 AUG 22 AM 10:55  
 STATE ENGINEERS OFFICE