

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 48919  
Permit No. 107  
Basin 107

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32909

1. OWNER Glenn Peters ADDRESS AT WELL LOCATION 3550 Burke Drive  
MAILING ADDRESS P O Box 246  
Wellington, NV 89444

2. LOCATION NW 1/4 SW 1/4 Sec. 24 T 12 N S R 23 E Lyon County  
PERMIT NO. 16798 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay w/sand layers		0	20	20
Clay w/gravel & sand layers		20	25	5
Coarse sand		25	43	18
Clay w/coarse sand		43	95	52
Coarse sand		95	130	35
Fine sand		130	180	50
Clay w/sand layers		180	215	35

Note: Jason King gave permission for 18 ft seal

8. WELL CONSTRUCTION  
Depth Drilled 220 Feet Depth Cased 215 Feet

HOLE DIAMETER (BIT SIZE)  
From 24 Inches To 0 Feet  
From 0 Feet To 220 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
30	culvert	12 ga	+2	18
16	42.05	.250	+2	95
16	42.05	.250	195	215

Perforations:  
Type perforation x HD Screen  
Size perforation .050  
From 95 feet to 195 feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 18  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
Static water level 18 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature NO.M °F Quality fair

Date started July 17 1995  
Date completed July 18 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
	not tested		

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Humboldt Drilling & Pump Co Inc. Contractor  
Address P O Box 590 Contractor  
Winnemucca, NV 89446  
Nevada contractor's license number issued by the State Contractor's Board 015234  
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1562  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 8-15-95

RECEIVED  
95 AUG 17 AM 10:25  
STATE ENGINEERS OFFICE