

OFFICE USE ONLY  
 Log No. 48920  
 Permit No. 090  
 Basin 090

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32116

1. OWNER Gas A Mart ADDRESS AT WELL LOCATION 217 Kingsbury Dr  
 MAILING ADDRESS 217 Kingsbury Dr Stateline, NV 89803  
 2. LOCATION NW 1/4 NW 1/4 Sec. 26\*\* T. 13 N/S R. 18 E Douglas County  
 PERMIT NO. M/O 780 C N/A N/A  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

NW 10	Material	Water Strata	From	To	Thick-ness
	Asphalt		0	3"	3"
	Sand & gravel		3"	4' 3 3/4'	
	Granite		4'	80'	76'
Hole was gravel packed with silica sand 2' bentonite plug placed above sand pack Cemented to surface & set monument flush with asphalt					

8. WELL CONSTRUCTION  
 Depth Drilled 80 Feet Depth Cased 80 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
6" Inches 0 Feet 80 Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	pvc	sch * 40	-3"	80

Perforations:  
 Type perforation Millslot  
 Size perforation .020  
 From 10 feet to 80 feet  
 From feet to feet  
 From feet to feet  
 From feet to feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 6'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 8 feet to 80 feet

9. WATER LEVEL  
 Static water level 55' feet below land surface  
 Artesian flow G.P.M. P.S.I.  
 Water temperature C °F Quality

Date started April 27, 1995.  
 Date completed April 27, 1995.

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Hackworth Drilling, Inc. Contractor  
 Address P.O. Box 850 Contractor  
Elko, NV 89803  
 Nevada contractor's license number issued by the State Contractor's Board 020582  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 5-7-95

95 MAY -8 P1231  
 STATE ENGINEER