

OFFICE USE ONLY
 Log No. 48929
 Permit No. 103
 Basin. 103
 NOTICE OF INTENT NO. 26758

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Vic De Blasio / Rainbow Homes ADDRESS AT WELL LOCATION 125 Comstock Dayton, Nev.
 MAILING ADDRESS _____
 2. LOCATION SE 1/4 SE 1/4 Sec. 9 T. 16 N/S R. 22 E. Lyon County
 PERMIT NO. N/A Issued by Water Resources 110-371-22 Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Hand

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Boulders And Soil</u>		<u>0</u>	<u>4</u>	<u>4</u>
<u>Boulders</u>		<u>4</u>	<u>80</u>	<u>76</u>
<u>Tan Clay</u>		<u>80</u>	<u>121</u>	<u>41</u>
<u>Boulders And Gravel</u>		<u>121</u>	<u>185</u>	<u>64</u>

8. WELL CONSTRUCTION
 Depth Drilled 185 Feet Depth Cased 185 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 185 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.00</u>	<u>3/16</u>	<u>41</u>	<u>185</u>

Perforations:
 Type perforation Touch cut
 Size perforation 1 1/4 x 60 in. 5 Rows
 From 165 feet to 185 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 0-50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 185 feet

9. WATER LEVEL
 Static water level 70 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Teach Drilling Inc Contractor
 Address PO Box 599 Silver Springs NV 89429 Contractor
 Nevada contractor's license number 0031841 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1827
 Signed [Signature]
 By driller performing actual drilling on site or Contractor
 Date 7-20-95

Date started 7-11, 1995
 Date completed 7-13, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Developed for 2 Hours and produced about 50 Gallons A min</u>			

RECEIVED
 05 AUG 17 PM 2:37
 STATE ENGINEERS OFFICE