

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 28106

1. OWNER Richard + Pam Brown ADDRESS AT WELL LOCATION 4635 BRAYTON  
 MAILING ADDRESS 3565 BROWN LANE WINN, NV. 89445  
 2. LOCATION NW 1/4 SE 1/4 Sec. 7 T. 35 NS R. 38 E Humboldt County  
 PERMIT NO. Domestic Issued by Water Resources 10 482-11 Parcel No. N/A Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	10	10'
COBBLES SAND GRAVEL		10	50	40'
SAND GRAVEL CLAY		50	110	60'
HARD ROCK FRACTURED	171	110	205	95'
MASSIVE LOST CIRCULATION				

'95 MAY -4 AIT 14  
 STATE ENGINEERS OF NV

8. WELL CONSTRUCTION  
 Depth Drilled 205 Feet Depth Cased 193 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 Feet To 125 Feet  
10.625 Inches  
 From 125 Feet To 205 Feet  
6.062 Inches

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	12	.188	+1	125
5.562	10	.188	105	193

Perforations:  
 Type perforation FACTORY SAW CUTS  
 Size perforation 3/32  
 From 175 feet to 193 feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 75'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 75 feet to 125 feet

9. WATER LEVEL  
 Static water level 146 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality GOOD

Date started 3 17, 1995  
 Date completed 3 23, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15</u>	<u>?</u>	<u>3 hrs</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name FRED ANDERSON Contractor  
 Address 10760 GRASS VALLEY ROAD Contractor  
WINN, NV. 89445  
 Nevada contractor's license number issued by the State Contractor's Board 024167  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 01375  
 Signed [Signature]  
 Date 3-25-95