

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26585

1. OWNER JOHN DECARLO ADDRESS AT WELL LOCATION 1476 WILLOW CREEK  
MAILING ADDRESS GARDNERVILLE GARDNERVILLE

2. LOCATION Nw 1/4 SW 1/4 Sec. 35 T 13 R 20 E DOUGLAS County  
PERMIT NO. 23-540-17 WILLOW CREEK  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MVD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY/COBEL'S		0	9	9
CEMENTED GRAVEL/COBEL'S		9	29	20
SANDY CLAY		29	34	5
CEMENTED GRAVEL		34	44	10
SANDY CLAY/GRAVEL		44	62	18
SANDY CLAY		62	97	35
CLAY		97	103	6
SAND GRAVEL	✓	103	132	29
CEMENTED GRAVEL		132	146	14
SAND GRAVEL	✓	146	160	14

95 MAY 24 AM 11:47  
STATE ENGINEER

8. WELL CONSTRUCTION  
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)  
From To  
10 5/8 Inches 0 Feet 100 Feet  
9 7/8 Inches 100 Feet 160 Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>±1</u>	<u>160</u>

Perforations:  
Type perforation FACTORY SLOTTED  
Size perforation 3 x 3/32  
From 140 feet to 160 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 100  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 100 feet to 160 feet

9. WATER LEVEL  
Static water level 40 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature 60.0 °F Quality GOOD

Date started 5-15 1995  
Date completed 5-18 1995

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIRL</u>	<u>25+</u>	<u>—</u>	<u>1</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name EDDCO EXPLORATION, INC. Contractor  
Address 7780 CURRY RD Contractor  
FALLON, NV 89406  
Nevada contractor's license number issued by the State Contractor's Board 27673  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726  
Signed Pat A. Moore  
By driller performing actual drilling on site for contractor  
Date 5-18-95