

Log No. 48957
 Permit No. _____
 Basin. 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26583

1. OWNER JERRY PALMER ADDRESS AT WELL LOCATION 1670 CHOWBUCK MINDEN, NV
 MAILING ADDRESS 2777 ESAW MINDEN, NV
 2. LOCATION NE 1/4 NW 1/4 Sec 35 T 14 N3 R 20 E DOUGLAS County
 PERMIT NO. 21-250-56 Subdivision Name JOHNSON LANE
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand</u>		<u>0</u>	<u>17</u>	<u>17</u>
<u>Sandy clay w/ coarse sand</u>		<u>17</u>	<u>36</u>	<u>19</u>
<u>Sandy clay w/ gravel</u>		<u>36</u>	<u>75</u>	<u>39</u>
<u>gravel</u>		<u>75</u>	<u>83</u>	<u>8</u>
<u>Sandy clay w/ some gravel</u>		<u>83</u>	<u>129</u>	<u>46</u>
<u>Grey Sandy clay w/ sand</u>		<u>129</u>	<u>199</u>	<u>70</u>
<u>Brn. Sandy clay w/ some gravel</u>		<u>199</u>	<u>205</u>	<u>6</u>
<u>Brn. Sandy clay w/ coarse sand</u>		<u>205</u>	<u>271</u>	<u>66</u>
<u>Grey Sandy clay w/ gravel</u>	<u>WV</u>	<u>271</u>	<u>295</u>	<u>24</u>
<u>Grey clay</u>		<u>295</u>	<u>300</u>	<u>5</u>

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 300 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 3/8 Inches 0 Feet 50 Feet
9 3/8 Inches 50 Feet 300 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>15</u>	<u>.188</u>	<u>+2</u>	<u>300</u>

Perforations:
 Type perforation Factory slotted T.C.
 Size perforation 3 x 3/32
 From T.C. 220 feet to 280 feet
 From Factory 280 feet to 300 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 300 feet

9. WATER LEVEL
 Static water level 173 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDD CO EXPLORATION, INC Contractor
 Address 7780 CURRY RD Contractor
FALLON, NV 89406
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
 Signed Jerald W. Diamond
 By driller performing actual drilling on site or contractor
 Date 5-18-95

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>25+</u>	<u>—</u>	<u>3</u>

Date started 5-15, 1995
 Date completed 5-18, 1995