

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24658

1. OWNER Farrel Hansen ADDRESS AT WELL LOCATION North End Ely City Limits
 MAILING ADDRESS Box 736
Ely, NV 89301

2. LOCATION SW 1/4 SE 1/4 Sec. 10 T 16 N&S R 63 E White Pine County
 PERMIT NO. N/A Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	5	5
Clay & Gravel		5	10	5
Water Bearing Sand & Gravel	x	10	35	25
Clay & Gravel		35	60	25
Water Bearing Sand & Gravel	x	60	75	15
Clay & Gravel		75	100	25
Water Bearing Sand & Gravel	x	100	136	36

8. WELL CONSTRUCTION
 Depth Drilled 136 Feet Depth Cased 136 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>12 1/2</u> Inches	<u>0</u> Feet <u>136</u> Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>136</u>
_____	_____	_____	_____	_____

Perforations:
 Type perforation Factory
 Size perforation 1/8" x 2 1/2" 8 rows
 From 56 feet to 136 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 55 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 55 feet to 136 feet

9. WATER LEVEL
 Static water level 6 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

Date started May 16, 19 95
 Date completed May 18, 19 95

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>200</u>	<u>114</u>	<u>1</u>
_____	_____	_____	_____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc. Contractor
 Address 557 Ely Avenue Contractor
Ely, Nv 89301
 Nevada contractor's license number issued by the State Contractor's Board 14790
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641
 Signed Jerrold D. Christiansen
 By driller performing actual drilling on site or contractor
 Date May 22, 1995

'95 MAY 24 10:43
 STATE ENGINEERS