

OFFICE USE ONLY  
 Log No. 48913  
 Permit No. \_\_\_\_\_  
 Basin 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26604  
1486 CHERRY CHERY,  
GARDNERVILLE

1. OWNER BLADES CONSTRUCTION ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS GARDNERVILLE \_\_\_\_\_  
 2. LOCATION NE 1/4 SE 1/4 Sec 35 T. 13 N. R. 20 E. DOUGLAS County  
 PERMIT NO. \_\_\_\_\_ Parcel No. 23-473-24 Subdivision Name WILDFLOWER  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other m.v.d.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SANDY CLAY-GRAVEL</u>		<u>0</u>	<u>4</u>	<u>4</u>
<u>CEMENTED GRAVEL</u>		<u>4</u>	<u>24</u>	<u>20</u>
<u>SANDY CLAY</u>		<u>24</u>	<u>61</u>	<u>37</u>
<u>SANDY CLAY-GRAVEL</u>		<u>61</u>	<u>110</u>	<u>49</u>
<u>SAND-GRAVEL</u>		<u>110</u>	<u>146</u>	<u>36</u>
<u>SANDY CLAY</u>		<u>146</u>	<u>178</u>	<u>32</u>
<u>SAND-GRAVEL</u>	<input checked="" type="checkbox"/>	<u>178</u>	<u>190</u>	<u>12</u>
<u>CLAY</u>		<u>190</u>	<u>201</u>	<u>11</u>
<u>SANDY CLAY-GRAVEL</u>		<u>201</u>	<u>225</u>	<u>24</u>
<u>SAND-GRAVEL/STRAK'S</u>	<input checked="" type="checkbox"/>	<u>225</u>	<u>240</u>	<u>15</u>

8. WELL CONSTRUCTION  
 Depth Drilled 240 Feet Depth Cased 240 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To \_\_\_\_\_ Feet  
 From 9 7/8 Inches To 50 Feet  
 From \_\_\_\_\_ Inches To \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.183</u>	<u>41</u>	<u>240</u>

Perforations:  
 Type perforation FACTORY SLOTTED  
 Size perforation 3 X 3/32  
 From 180 feet to 200 feet  
 From 200 feet to 240 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 240 feet

9. WATER LEVEL  
 Static water level 72 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality GOOD

Date started 7-11, 1995  
 Date completed 7-18, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>AIR</u>	<u>25+</u>	<u>-</u>	<u>1</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDDCO EXPLORATION, INC Contractor  
 Address 7780 CURRY RD. Contractor  
FALLON, NV 89406  
 Nevada contractor's license number issued by the State Contractor's Board 27673  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726  
 Signed Paul J. Moore  
 By driller performing actual drilling on site or Contractor  
 Date 7-18-95