

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26594

1. OWNER RICK EATON CONSTRUCTION ADDRESS AT WELL LOCATION 1734 SUNSET  
 MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE

2. LOCATION SW 1/4 SE 1/4 Sec. 35 T. 13 N. R. 20 E DOUGLAS County  
 PERMIT NO. 23-560-06 Subdivision Name WILDFLOWER  
Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY/COBELS		0	6	6
CEMENTED GRAVEL/COBELS		6	12	6
CEMENTED GRAVEL		12	15	3
CEMENTED GRAVEL/COBELS		15	21	6
CEMENTED GRAVEL		21	43	24
SAND/GRAVEL		43	45	2
SANDY CLAY		45	52	7
SANDY CLAY/GRAVEL		52	64	12
SAND/GRAVEL		64	72	8
CEMENTED GRAVEL		72	88	16
SANDY CLAY		88	90	2
CEMENTED GRAVEL		90	105	15
SANDY CLAY/GRAVEL		105	162	57
SAND/GRAVEL		162	184	22
SANDY CLAY/GRAVEL		184	214	30
CLAY		214	218	4
SAND/GRAVEL	✓	218	234	16
SAND	✓	234	236	2
SANDY CLAY/GRAVEL		236	240	4

8. WELL CONSTRUCTION  
 Depth Drilled 240 Feet Depth Cased 240 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 50 Feet  
9 7/8 Inches 50 Feet 240 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	240

Perforations:  
 Type perforation FACTORY SLOTTED  
 Size perforation 3 x 3/32  
 From 220 feet to 240 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 240 feet

9. WATER LEVEL  
 Static water level 55 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality GOOD

Date started 6-21, 1995  
 Date completed 6-27, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>257</u>	<u>—</u>	<u>1</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDDCO EXPLORATION, INC Contractor  
 Address 7780 CURRY RD. Contractor  
FALLOON, NV 89406  
 Nevada contractor's license number issued by the State Contractor's Board 27673  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726  
 Signed Pat J. Moore  
 By driller performing actual drilling on site on Contractor  
 Date 6-28-95