

OFFICE USE ONLY
 Log No. 4827
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28911
 ADDRESS AT WELL LOCATION 1603 TERRY ANN MINDEN, NV

1. OWNER JERRY PALMER CONST. ADDRESS AT WELL LOCATION 1603 TERRY ANN MINDEN, NV
 MAILING ADDRESS MINDEN, NV

2. LOCATION NW 1/4 SW 1/4 Sec. 26 T. 14 N. R. 20 E. DOUGLAS County
 PERMIT NO. _____ Parcel No. 21-240-04 Subdivision Name JOHNSON LANE
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand</u>		<u>0</u>	<u>12</u>	<u>12</u>
<u>Sandy clay / sm gravel</u>		<u>12</u>	<u>80</u>	<u>68</u>
<u>Sandy clay</u>		<u>80</u>	<u>95</u>	<u>15</u>
<u>Sandy clay / sm gravel</u>		<u>95</u>	<u>196</u>	<u>101</u>
<u>Sandy clay</u>		<u>196</u>	<u>210</u>	<u>14</u>
<u>Sm gravel / sandy clay</u>	<u>/</u>	<u>210</u>	<u>230</u>	<u>20</u>
<u>Sandy clay / coarse</u>		<u>230</u>	<u>275</u>	<u>45</u>
<u>Sm gravel / sandy clay</u>	<u>//</u>	<u>275</u>	<u>296</u>	<u>21</u>
<u>Sandy clay / sand</u>		<u>296</u>	<u>300</u>	<u>4</u>

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 50 Feet
9 7/8 Inches 50 Feet 300 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>1.88</u>	<u>12</u>	<u>300</u>

Perforations:
 Type perforation Factory slotted / T.L.
 Size perforation 3 x 3/32
 From T.L. 210 feet to 230 feet
 From Factory 280 feet to 300 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 300 feet

9. WATER LEVEL
 Static water level 152 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD. Contractor
FALLON, NV 89406
 Nevada contractor's license number 27673
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1535
 Division of Water Resources, the on-site driller
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 6-28-95

Date started 6-22, 1995
 Date completed 6-28, 1995

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>20+</u>	<u>—</u>	<u>2</u>