WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48919
Permit No.
Basin 105

NOTICE OF INTENT NO. 26607

1. OWNER PHILIP + LINDA SNOWDON
MAILING ADDRESS P.O. BOX 128
GARDNERVILLE, NV

ADDRESS AT WELL LOCATION 1939 HORSEBRUSH
GARDNERVILLE

2. LOCATION NW ¼ SE ¼ Sec. 36 T. 13 (N)S R. 20 E DOUGLAS County
PERMIT NO. — Issued by Water Resources
23-472-12 Parcel No.
WILDFLOWER Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY/COBBLES		0	4	4
CEMENTED GRAVEL		4	15	11
SANDY CLAY		15	17	2
CEMENTED GRAVEL		17	33	16
SANDY CLAY		33	48	15
CLAY		48	61	13
SANDY CLAY		61	189	128
SANDY CLAY/GRAVEL		189	198	9
BASALT FRACTURES		198	210	12
SANDY CLAY/GRAVEL		210	274	64
SANDY CLAY (GRAY)		274	615	341
CLAY		615	665	50
SAND	✓	665	666	1
CLAY		666	674	8
SAND	✓	674	675	1
CLAY		675	676	1
SANDY CLAY (STREAKS)	✓	676	684	8
SANDY CLAY (STREAKS)	✓	684	700	16

Date started 6-6, 1995
Date completed 6-21, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	25+	—	4

8. WELL CONSTRUCTION
Depth Drilled 700 Feet Depth Cased 700 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8	Inches	0 Feet	50 Feet
9 7/8	Inches	50 Feet	700 Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	0	700

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 3 X 3/32
From 660 feet to 700 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 700 feet

9. WATER LEVEL
Static water level 250 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature WARM °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDCO EXPLORATION, INC. Contractor
Address 7780 CURRY RD. Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
Signed Pat J. Mor By driller performing actual drilling on site or contractor
Date 6-21-95

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627