WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48971
Permit No.
Basin 187

NOTICE OF INTENT NO. 21103

1. OWNER Joann T. Holt
MAILING ADDRESS P.O. Box 249 Enterprise, Ut. 84725
ADDRESS AT WELL LOCATION Lake Valley, Nev.

2. LOCATION SW ¼ NW ¼ Sec. 35 T. 6 N/S R. 66 E. Lincoln County
PERMIT NO. 59117 (Issued by Water Resources) Parcel No. — Subdivision Name —

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [X] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay Sand		1	18	18
Clay		18	28	10
Sand gravel		28	64	36
Clay		64	72	8
Sand gravel		72	86	14
Clay Sand		86	102	16
Sand gravel		102	110	8
Clay		110	116	6
Sand gravel		116	120	4
Clay Sand		120	170	50
Sand gravel		170	182	12
Clay Sand		182	198	16
Sand gravel		198	210	12
little Clay, Sand		210	247	37
Sand gravel		247	266	19
Clay Sand		266	275	9
little Clay Sand		275	290	15
Sand gravel		290	292	2
Clay Sand		292	295	3
Sand gravel		295	350	55
Clay		350	366	16
Sand gravel		366	395	29

Date started July 1, 1995
Date completed July 5, 1995

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled 395 Feet Depth Cased 395 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
28	0	395

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	42 lb	.250	18" +	395

Perforations:
Type perforation Mill
Size perforation 5/32 x 2.5
From 195 feet to 395 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 395 feet

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Gardner Drilling (Contractor)
Address Box 18 (Contractor)
New Castle, Ut. 84756
Nevada contractor's license number issued by the State Contractor's Board 0031759
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1710
Signed Dale Gardner (By driller performing actual drilling on site or contractor)
Date July 10, 1995