WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 48976
Permit No.
Basin 092 B

NOTICE OF INTENT NO. 23809

1. OWNER ED GRIFFITH
MAILING ADDRESS 1000 B VIRBEL LANE
RENO, NEVADA 89502

ADDRESS AT WELL LOCATION 9430 ARROWHEAD WAY
RENO, NEVADA 89506

2. LOCATION NE ¼ NW ¼ Sec. 11 T. 20 N/S R. 19 E. WASHOE County
PERMIT NO. (Issued by Water Resources) 088-130-03 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| TAN YELLOW BROWN | | 0 | 17 | |
| WHITE D.G. FIRM | | | | |
| GREEN WHITE BROWN | | | | |
| SEMI DECOMPOSED | | | | |
| GRANITE HARD & FRACTURED | | 17 | 250 | |
| TD 250 | | | | |

Date started 6-30, 19 95
Date completed 7-3, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 12 | | 2 |

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 5/8 | Inches | 0 Feet | 55 Feet |
| 8 1/2 | Inches | 55 Feet | 180 Feet |
| 8 | Inches | 180 Feet | 250 Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 1292 | 188 | +1 1/2 | 250 |

Perforations:
Type perforation FACTORY SAWED
Size perforation 3/32 x 3"
From 230 feet to 210 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55 Portland Cem.
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 250 feet to 55 feet

9. WATER LEVEL
Static water level 105 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. PUMP & WELL SERVICE, INC. (Contractor)
Address 1800 1/2 FRAZER AVENUE (Contractor)
SPARKS, NEVADA 89431

Nevada contractor's license number issued by the State Contractor's Board 35387A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511
Signed Larry Welch (By driller performing actual drilling on site or contractor)
Date 7-5-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627