

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27P23

1. OWNER B. J. Downey ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 4662 W Warm Springs Las Vegas, NV 89118 2289 Meadowlark Ct Minden, NV 89423
 2. LOCATION NW 1/4 NE 1/4 Sec 10 T. 13 N/S R. 17 E Douglas County
 PERMIT NO. 17-112-05 Genoa Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Siltstone + clay</u>	<u>X</u>	<u>0</u>	<u>15</u>	
<u>clay</u>		<u>15</u>	<u>50</u>	
<u>Gravel & clay</u>		<u>50</u>	<u>80</u>	
<u>sand, rock & clay</u>		<u>80</u>	<u>160</u>	

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 9 7/8 Inches To 0 Feet
160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>7</u>	<u>.188</u>	<u>0</u>	<u>160</u>

Perforations:
 Type perforation Factory Perforated
 Size perforation 3 x 7/16
 From 140 feet to 160 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 160 feet

9. WATER LEVEL
 Static water level Artesian feet below land surface
 Artesian flow 1-2 gpm G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 6/27 1995
 Date completed 6/29 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>		<u>4 HRS</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Rouchack Drilling Inc Contractor
 Address P.O. Box 1359, Minden, NV 89423 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 021268
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 13807
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 7/5/95