WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48990
Permit No.
Basin

NOTICE OF INTENT NO. 14367

1. OWNER RUTH KUNCH
MAILING ADDRESS 6231 E. KATIE LN.
PAHRUMP NV. 89041
ADDRESS AT WELL LOCATION 6231 E. KATIE LN.

2. LOCATION S W ¼ N W ¼ Sec. 15 T. 21s N/S R 54e E NYE County
PERMIT NO. Issued by Water Resources | Parcel No. 45-131-52 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAVEL		0	18	18
BROWN CLAY		18	30	12
TIGHT GRAVEL		30	50	20
SANDY GRAVEL		50	58	8
RED CLAY		58	62	8
LOOSE GRAVEL		62	110	48
LOOSE GRAVEL@ CLAY		110	250	140
COURSE GRAVEL	X	250	265	15

DCNR/DWR Received OCT 16 1995 LAS VEGAS OFFICE

Date started SEP. 4, 19 95
Date completed SEP. 15, 19 95

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100	0	½

8. WELL CONSTRUCTION
Depth Drilled 265 Feet Depth Cased 265 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches	0 Feet	265 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	18	203	0	265

Perforations:
Type perforation ¼X4 FACTORY
Size perforation ¼ X4
From 230 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 265 feet

9. WATER LEVEL
Static water level 23 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LARRY JENKINS Contractor
Address PO. BOX 3392 Contractor
PAHRUMP NV. 89041
Nevada contractor's license number issued by the State Contractor's Board x~~1916~~ 0035901
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916
Signed Larry Jenkins
By driller performing actual drilling on site or contractor
Date SEPT 29 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627