WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 48993
Permit No.
Basin 162

NOTICE OF INTENT NO. 13184

1. OWNER Gary Mitchel
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ NE ¼ Sec. 18 T. 20-S N/S R. 53 E. Nye County
PERMIT NO. APN 36-171-23 (Issued by Water Resources) | 5 acres (Parcel No.) | Charles Lynch (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
White Clay		4	12	8
Grey Clay		12	28	16
Brown Clay		28	48	20
Granular White Clay		48	60	12
Soft Brown Clay	x	60	110	50
Grey Clay		110	148	38
Hard Lime		148	152	4
Soft Brown Clay	x	152	172	20
Brown Clay		172	200	28

DCNR/DWR Received OCT 13 1995 LAS VEGAS OFFICE

Date started September 27, 1995
Date completed September 29, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	¼

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches	0 Feet	200 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 in	18lbs.	.188	0	200

Perforations:
Type perforation Torch Cut
Size perforation ¼ in width 8 in long
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 53 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles Nyberg (Contractor)
Address HCR 77 BOX 36525 Pahrump, NV 89041 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 7484
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725

Signed Charles Nyberg (By driller performing actual drilling on site or contractor)
Date October 3, 1995

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627