

OFFICE USE ONLY
 Log No. 49241
 Permit No. _____
 Basin 101

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28708

1. OWNER Tony Kopas 170 Industrial ADDRESS AT WELL LOCATION 5984 Hooper Pl
 MAILING ADDRESS 170 Industrial way Fallon NV 89406

2. LOCATION SW 1/4 NW 1/4 Sec. 29 T. 19 N/S R. 28 E Churchill County
 PERMIT NO. 008-572-18 Riversedge Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sands		0	15	15
Brown Clay		15	18	3
Multi Colored ^{Brown} Sands		18	27	9
Brown Sands		27	50	23
Brown Sands		50	53	3
Brown Clay		53	58	5
Brown Sands		58	67	9
Brown Sands		67	87	20
Grey Sands		87	93	6
Brown Clay		93	96	3
Brown gravels	96	96	111	15

8. WELL CONSTRUCTION
 Depth Drilled 111 Feet Depth Cased 111 Feet
 HOLE DIAMETER (BIT SIZE)
 From 6 1/8 Inches To 80 Feet
 From 10 Inches To 111 Feet
 From _____ Inches To _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.8	188	0	111

Perforations:
 Type perforation Factory
 Size perforation 0060
 From 105 feet to 110 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 10 feet 6 inches below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.0 °F Quality OK

Date started March 23, 1995
 Date completed March 24, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>		<u>1/2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WELCO CORP Contractor
 Address 335 N Broad way Contractor
Fallon NV 89406
 Nevada contractor's license number 11752
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 772
 Division of Water Resources, the on-site driller
 Signed Jesus Manicurnem
 By driller performing actual drilling on site or contractor
 Date 3-24-95