WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

12 DDDA

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 79056
Permit No.
Basin 088

NOTICE OF INTENT NO. 29541

Consultant:
~~1. OWNER~~ Ground Water Resources Consult. Inc
MAILING ADDRESS 6200 E. 14th Street, Suite A200
Tucson, AZ 85711

ADDRESS AT WELL LOCATION Rocketdyne NV Field Lab
2555 Whiskey Springs Rd
Reno, NV 89510

2. LOCATION SE ¼ SE ¼ Sec 12 T 22N N/S R 21 E Washoe County
PERMIT NO. Area D (Issued by Water Resources) 077-110-01 (B) (Parcel No.) To identify 2 of 2 wells Palomino Valley Unit 1 (Subdivision Name) 12.2.1.5

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DOMESTIC WELL ABANDONMENT:		of log 16247		
Static water level @ 65 feet				
Total Depth at 238 feet				
Equipment used:				
T4 W-1050 Drill with 2 man crew, support truck				
Down hole air operated perforator				
Cement pump & mixer				
Material used:				
102 sacks of Portland Cement type II				
½ sack Bentonite 2%				
Method used:				
Attempt to pull casing				
Perforate casing from 50 to 110'. Have liner at 110ft.				
Evidence of existing seal berween 0 to 50 feet				
Install tremie pipe, pump cement through pipe				
with 98 sacks, from bottom to surface				
Fluid level up to surface, let settle				
4 sacks used to top off at surface.				
Location: 270' W. of E. propline & 800' S. of				
center of road to the N.				

Date started 4-20-95, 19
Date completed 4-20-95, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)
Inches From Feet To Feet
Inches From Feet To Feet
Inches From Feet To Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, Nevada 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed (By driller performing actual drilling on site or contractor)
Date May 2, 1995

ABANDON

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627