PPW-68

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49069
Permit No.
Basin 061

NOTICE OF INTENT NO. 29517

1. OWNER Barrick Goldstrike
MAILING ADDRESS P.O. Box 29
Elko, NV 89801

ADDRESS AT WELL LOCATION
Barrick Goldstrike Mine

2. LOCATION SE ¼ NW ¼ Sec. 19 T 36 N/S R 50 E EUREKA County

PERMIT NO. 55141 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay & Sandstone		0	135	135
Brown clay		135	195	60
Brown clay & rock		195	250	55
Brown clay		250	325	75
Brown clay & gray rock		325	355	30
Gray rock & some clay		355	394	40
Brown & black rock		395	455	60
Gray rock		455	480	25
Black rock		480	570	90

Date started July 13, 19 95
Date completed July 16, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 570 Feet Depth Cased 560 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
20	0	40
12 1/4	40	570

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16"	62.58	.375	+2	38
6	17.02	.250	+2	60

Perforations:
Type perforation Louvered
Size perforation .125
From 60 feet to 560 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 560 feet

9. WATER LEVEL
Static water level 391 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 80 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Lang Exploratory Drilling (Contractor)
Address 2286 West 1500 South (Contractor)
Salt Lake City, UT 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1800
Signed Victor Hernandez (By driller performing actual drilling on site or contractor) Victor Hernandez
Date July 27, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627