

OFFICE USE ONLY
 Log No. 619105
 Permit No. 087
 Basin 087

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 232BL6

1. OWNER UNOCAL # 7207 ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 2515 KIETEKE LANE
RENO, NV. 89502
 2. LOCATION AD 1/4 DA 1/4 Sec. 24 T. 19 N S R. 19 E WASHOE County
 PERMIT NO. M/O-74Z Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other AUGER

6. LITHOLOGIC LOG MW-3

Material	Water Strata	From	To	Thick-ness
<u>BROWN SILTY SAND</u>	<u>-</u>	<u>0</u>	<u>2</u>	<u>2'</u>
<u>DARK BROWN SAND</u>	<u>8 1/2'</u>	<u>2'</u>	<u>10'</u>	<u>8'</u>
<u>YELLOW BROWN SILTY SAND</u>		<u>10'</u>	<u>15'</u>	<u>5'</u>
<u>DARK GRAY SAND</u>		<u>15'</u>	<u>22'</u>	<u>7'</u>
<u>DARK GRAY SILT</u>		<u>22'</u>	<u>24'</u>	<u>2'</u>
<u>DARK GRAY SAND</u>		<u>24'</u>	<u>25'</u>	<u>1'</u>

8. WELL CONSTRUCTION
 Depth Drilled 25 Feet Depth Cased 25 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 0 Feet 25 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>SCH. 40</u>	<u>PVC</u>	<u>0</u>	<u>25</u>

Perforations:
 Type perforation FACTORY SLOT
 Size perforation 0.020"
 From 5 feet to 25 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 4' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 4 feet to 25 feet

9. WATER LEVEL
 Static water level 8.5' feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature COLD °F Quality N/A

Date started 12/13 1993
 Date completed 12/13 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
	<u>N/A</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ANDRESEN EXPLORATION DRILLING Contractor
 Address 1635 BELFORD RD. Contractor
RENO, NV. 89509
 Nevada contractor's license number 0034525
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1028
 Division of Water Resources, the on-site driller
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 6/13/94