

OFFICE USE ONLY
 Log No. 49130
 Permit No.
 Basin

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16718


1. OWNER Raymond Siefried ADDRESS AT WELL LOCATION 3731 E. Savoy Blvd.
 MAILING ADDRESS

2. LOCATION NW 1/4 SE 1/4 Sec. 19 T 21-S N/S R 54 E Nye County
 PERMIT NO. 45-243-34 Parcel No. Parcel 4 Subdivision Name
Issued by Water Resources

3. WORK PERFORMED New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|----------------------|--------------|------|-----|------------|
| Surface | | 0 | 4 | 4 |
| Brown clay | | 4 | 16 | 12 |
| Brown clay & caliche | | 16 | 34 | 18 |
| Brown clay | | 34 | 46 | 12 |
| Brown clay & caliche | X | 46 | 72 | 26 |
| Limestone | | 72 | 76 | 4 |
| Brown clay & caliche | | 76 | 106 | 30 |
| Limestone | | 106 | 110 | 4 |
| Brown clay & caliche | X | 110 | 125 | 15 |
| Brown clay | | 125 | 140 | 15 |



8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 0 Feet 140 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 8 5/8 | 16.94 | .188 | 0 | 100 |
| 8 5/8 | 18.26 | .203 | 100 | 140 |

Perforations:
 Type perforation Torch Cut
 Size perforation 1/2" width 8" long
 From 100 feet to 140 feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 54 feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature °F Quality

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Jim Pike Well Drilling, LLC Contractor
 Address P.O. Box 56 Contractor
Pahrump, NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 17563A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1812
 Signed Jim H. Pike
 By driller performing actual drilling on site or contractor
 Date November 17, 1995

Date started November 5, 19 95
 Date completed November 5, 19 95

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|-----------|-------------------------------|--------------|
| <u>20</u> | <u>4</u> | <u>1/4</u> |