

Log No. 49165
 Permit No. _____
 Basin. 101

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29331
725 E Stillwater
Fallon NV

1. OWNER Churchill co. school/Dist. ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 290 N. Sherman St _____
 2. LOCATION NW 1/4 NE 1/4 Sec 31 T. 19 N. R. 29 E _____
 PERMIT NO. MO-875A Parcel No. 001 711 05 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Silt - yellowish Brown</u>		<u>0</u>	<u>10'</u>	
<u>SAND w/ silt Dark yellowish Brown</u>		<u>10'</u>	<u>15'</u>	
<u>Silt Dark yellowish brown</u>		<u>15'</u>	<u>21.5'</u>	

8. WELL CONSTRUCTION
 Depth Drilled 27.5 Feet Depth Cased 20 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 21.5
 Inches _____ Feet _____
 _____ Inches _____ Feet _____
 _____ Inches _____ Feet _____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>		<u>sch 40</u>	<u>0</u>	<u>5</u>

Perforations:
 Type perforation .010
 Size perforation _____
 From 5 feet to 20 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 4' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 4 feet to 21.5 feet

9. WATER LEVEL
 Static water level 7.8' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

VEW-6
 Date started 5-23 19 95
 Date completed 5-23 19 95

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name NV. Drilling Inc. Contractor
 Address 75 lewers creek Rd Contractor
Carson City NV
 Nevada contractor's license number 13697A
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1902
 Division of Water Resources, the on-site driller
 Signed John S. Reisel
 By driller performing actual drilling on site or contractor
 Date 7-31-95