

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32559

1. OWNER DENNIS & JEANNIE SMITH ADDRESS AT WELL LOCATION Same  
 MAILING ADDRESS 10745 Abilene  
Reno, Nevada 89506

2. LOCATION NE 1/4 SW 1/4 Sec. 24 T. 21N N/S R. 18 E Washoe County  
 PERMIT NO. 086-203-27 Silver Knolls  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
WELL DEEPENING:				
Fill, gray sand		180	185	5
Gray clay		185	218	33
Soft zone	X	218	229	11
Gray clay		229	245	16
Brown clay		245	247	2
Gray sand	X	247	269	22
Gray clay		269	270	1
Soft zone	X	270	276	6
Gray clay		276	277	1

RECEIVED  
 AUG 23 AM 10:29  
 STATE ENGINEERING OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 277 Feet Depth Cased 277 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
6 1/8 Inches 185 Feet 277 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"OD		.188	0	277

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around

From 212 feet to 272 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal deepening  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 180 feet to 277 feet

9. WATER LEVEL  
 Static water level 180 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 25 P.S.I.  
 Water temperature cold °F Quality clear

Date started 8-18-95, 19\_\_\_\_  
 Date completed 8-18-95, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370  
RENO, NEVADA 89510 Contractor

Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada driller's license number issued by the Division of Water Resources, on-site driller 923

Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date August 19, 1995