

Log No. 49180
Permit No. _____
Basin. 102

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34982

1. OWNER John Rush ADDRESS AT WELL LOCATION _____
MAILING ADDRESS 5265 Canyon View Dr. _____
SPARKS, NV _____
2. LOCATION NE 1/4 SE 1/4 Sec. 18 T 17 N/S R 25 E Lyon _____ County
PERMIT NO. 17-314-16 Parcel No. 3 Sagebrush #3 Subdivision Name

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock Air Other _____
5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	12	12
CLAY		12	13	1
COARSE SAND		13	15	2
SAND & CLAY		15	17	2
CLAY		17	20	3
SAND + GRAVEL		20	28	8
CLAY		28	30	2
GRAVEL		30	34	4
CLAY		34	60	26
SAND & GRAVEL	✓	60	68	8
CLAY		68	88	20

8. WELL CONSTRUCTION
Depth Drilled 88 Feet Depth Cased 88 Feet
HOLE DIAMETER (BIT SIZE)
From _____ Feet _____ Feet
6 Inches 0 Feet 88 Feet
6 Inches 0 Feet 88 Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>13.77</u>	<u>.188</u>	<u>0</u>	<u>88</u>

Perforations:
Type perforation Machined
Size perforation 1/2" x 3"
From _____ feet to 88 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal 55 Cement Grout
Placement Method: Pumped Concrete Grout
 Poured
Gravel Packed: Yes No Natural
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 37 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cold quality Good

Date started 27 June 1995
Date completed 3 July 1995

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
<u>Pump</u>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
G.P.M.	<u>30</u>	<u>34</u>	<u>10</u>
Draw Down (Feet Below Static)			
Time (Hours)			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon Cannon Jr. Contractor
Address 4555 Hurstwood Contractor
Silver Springs, NV 89429
Nevada contractor's license number issued by the State Contractor's Board 23317
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1455
Signed Vernon Cannon Jr.
By driller performing actual drilling on site or contractor
Date 18 July 95