

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32023

1. OWNER SHEILA SAYKO ADDRESS AT WELL LOCATION None  
MAILING ADDRESS RANDON ELKO, NV 89801  
2. LOCATION NE 1/4 NE 1/4 Sec. 5 T. 35 N. S. R. 56 E. ELKO County \_\_\_\_\_  
PERMIT NO. None Issued by Water Resources 26-009-01-9 Parcel No. Twin River Ranch's Lot 1, Blk 9 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil		0	1	1
Sand, gravel, cobbles		1	5	4
Sandy clay		54	185	180
Sand	✓	185	186	1
Sand & gravel	✓	186	205	9
Clay	✓	205	210	5
T.D. 210				

95 JUL 26 AM 130 STATE ENGINEERS

8. WELL CONSTRUCTION  
Depth Drilled 210 Feet Depth Cased 211 Feet  
HOLE DIAMETER (BIT SIZE)  
From \_\_\_\_\_ To \_\_\_\_\_  
10 Inches 0 Feet 60 Feet  
8 Inches 60 Feet 210 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12.92</u>	<u>.188</u>	<u>+1.5</u>	<u>210</u>

Perforations:  
Type perforation TORCH CUT  
Size perforation 1/8 x 4  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From 175 feet to 205 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal \_\_\_\_\_  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 50 feet to 210 feet

9. WATER LEVEL  
Static water level 140 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature Cold °F Quality Good

Date started 6-9, 1985  
Date completed 6-15, 1985

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>20</u>	<u>5</u>	<u>2.0</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name MUTH DRILLING CO Contractor  
Address 203 PINE ST. ELKO 89801 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 10819  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632  
Signed James Y. Muth  
By driller performing actual drilling on site or contractor  
Date 7-11-95