WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49196
Permit No.
Basin 8-1/04

NOTICE OF INTENT NO. 32991

1. OWNER Gary Hutchings
MAILING ADDRESS 710 W. Williams Ave.
Fallon NV 89406

ADDRESS AT WELL LOCATION
9210 Pioneer way
Fallon NV 89406

2. LOCATION SE ¼ SW ¼ Sec. 15 T. 19 N/S R. 27 E. churchill County
PERMIT NO. Issued by Water Resources | Parcel No. 7-151-56 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	15	15
Clay		15	25	10
Brown Sand		25	42	17
Fine Gray Sand		42	50	8
Brown Clay		50	52	2
Sand		52	64	12
Gray Sand		64	80	16
Brown Sand		80	95	15
Gray Clay		95	115	20
Gray Sand		115	137	22
Brown Sand		137	150	13

Date started June 30, 19 95
Date completed July 5, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	150 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	150

Perforations:
Type perforation MILL CUT
Size perforation 1/8
From 147 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100 ft.
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 150 feet

9. WATER LEVEL
Static water level 33 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling INC. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1753
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 7/7/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627