

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29555

1. OWNER Jerry Eldridge ADDRESS AT WELL LOCATION Lot 58 Argosy 14090 Red Rock Road  
 MAILING ADDRESS 1320 Plymouth Sparks, Nevada 89431 Reno, Nevada 89506  
 2. LOCATION NW 1/4 NE 1/4 Sec. 19 T. 22N N/S R. 19 E. Washoe County  
 PERMIT NO. 079-362-13 Red Rock Estates # 58  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	1	1
Brown Sandy Clay		1	20	19
Brown Clay with gravels		20	28	8
Brown Sandy Clay		28	111	83
Soft Zone (no Water)				
D.G. Sands	X	111	114	3
Brown Sandy Clay		114	185	71
Gray Clay		185	201	16
Black Clay		201	226	25
Soft Zone (5 GPM)	X	226	230	4
Black Clay		230	255	25
Gray Clay		255	270	15
Soft Zone (5 GPM)	X	270	273	3
Gray Clay		273	286	13
Soft Zone (5GPM)	X	286	290	4
Gray Clay		290	300	10

8. WELL CONSTRUCTION  
 Depth Drilled 300 Feet Depth Cased 300 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 50 Feet  
8 5/8 Inches 50 Feet 300 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	300

 Perforations:  
 Type perforation Factory Sawn Slot  
 Size perforation 3/32 x 3 x 5 around  
 From 250 feet to 270 feet  
 From 280 feet to 300 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 300 feet

Date started 7/10/95, 19\_\_\_\_  
 Date completed 7/11/95, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15</u>		

9. WATER LEVEL  
 Static water level 211 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 15 P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling Inc Contractor  
 Address P.O. Box 12370 Contractor  
Reno, Nevada 89510  
 Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed Wayne Drilling Inc  
 By driller performing actual drilling on site or contractor  
 Date July 17, 1995