

Log No. 49201
 Permit No. _____
 Basin 044

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28761

1. OWNER JONNY HEMBOCK ADDRESS AT WELL LOCATION B/K A Lot 4
 MAILING ADDRESS PO Box 1609 TWIN PEAKS RD
ELKO NV 89803

2. LOCATION NE 1/4 NW 1/4 Sec. 11 T. 35 N. S. R. 54 E ELKO County
 PERMIT NO. 05-52C-04-9 ADOBE RANCHOS Subdivision Name
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Loam		0	1	1
Cemented Gravel		1	45	44
CLAY		45	48	3
Cemented Gravel		48	143	105
Loose Gravel	X	143	144	1
Cemented Gravel		144	175	31
Loose Gravel	X	175	177	2
CLAY		177	212	35
Hard Rock		212	213	1
Red Rock FANter	X	213	224	11
Cemented Gravel		224	230	6

35 JUL 17 4:32 PM

8. WELL CONSTRUCTION
 Depth Drilled 15 230 Feet Depth Cased 230 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches 0 Feet 230 Feet
 To _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Pt. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>12.92</u>	<u>1.85</u>	<u>7.6</u>	<u>230</u>

Perforations:
 Type perforation slots
 Size perforation 3/16 x 3"
 From 216 feet to 230 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 52

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 52 feet to 230 feet

9. WATER LEVEL
 Static water level 140 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

Date started 6-12 1995
 Date completed 6-15 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50</u>	<u>NU</u>	<u>3</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Fertig Drilling Co Contractor
 Address PO Box 525 Contractor
ELKO NV 89801

Nevada contractor's license number issued by the State Contractor's Board 31904

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584

Signed Shane C. Fertig
 By driller performing actual drilling on site or contractor

Date 6-28-95