WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49204
Permit No.
Basin 105

NOTICE OF INTENT NO. 29434

1. OWNER Michael Construction
MAILING ADDRESS 773 Saddle Ct. Gardnerville NV. 89410
ADDRESS AT WELL LOCATION 773 Saddle Ct Gardnerville NV. 89410

2. LOCATION NW ¼ NE ¼ Sec. 24 T. 12 N/S R. 21 E. Douglas County
PERMIT NO. Issued by Water Resources | Parcel No. 29-462-60 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
overburden		0	3	3
Brown Sands with Hardpack Clay		3	18	15
Brown Dry Clay		18	60	42
Brown Gummy Clay		60	100	40
Hard Coarse Obsidian Gravels w/clay		100	130	30
Hard obsidian Gravels		130	170	40
Broken fractures w/Hard obsidian Gravels		170	200	30

JUL 18 '95 PM 12:20 STATE ENGINEER'S OFFICE

Date started 7-10, 19 95
Date completed 7-13, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20-25	30	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 1/4 Inches	0 Feet	200 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	200

Perforations:
Type perforation Mill Slot
Size perforation 3 X 3/32
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 100 feet below land surface
Artesian flow G.P.M. 20-25 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Company (Contractor)
Address 5551 Hwy 50 E #3 Carson City NV. 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack
By driller performing actual drilling on site or contractor
Date 7/17/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627