

OFFICE USE ONLY
 Log No. 49209
 Permit No. _____
 Basin. 049

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31168
Adobe Ht. Road

1. OWNER Kay Osteen ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 528 Sundial
Moab, UT 84532

2. LOCATION NE 1/4 SW 1/4 Sec. 1 T. 34 Q/S R. 54 E. Elko County
 PERMIT NO. 5-51D-12 Special Lands/Adobe Hts.
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	3	3
Sandstone		3	60	57
Blue Clay		60	260	200
Siltstone	X	260	280	20
Blue Clay		280	400	120
Siltstone	X	400	403	3
Blue Clay		403	500	97

8. WELL CONSTRUCTION
 Depth Drilled 500 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 500 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+1 1/2</u>	<u>500</u>

Perforations:
 Type perforation Millslot
 Size perforation 3/16 X 3

From _____ feet to _____ feet
 From 280 feet to 300 feet
 From 380 feet to 400 feet
 From 480 feet to 500 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 500 feet

9. WATER LEVEL
 Static water level 160 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 12-5 19 95
 Date completed 12-11 19 95

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15</u>		<u>5</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hackworth Drilling, Inc. Contractor
 Address P.O. Box 850 Contractor
Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board. 020582
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 1689

Signed Daniel Nelson
 By driller performing actual drilling on site or contractor
 Date 12-20-95

RECEIVED
 95 DEC 26 PM 2:43
 STATE ENGINEERING OFFICE