WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 09122
Permit No.
Basin 108

NOTICE OF INTENT 27141

1. OWNER Kathy + Dale PFAFFLE
MAILING ADDRESS 3890 Volo DR SAN JOSE, CA 95136
ADDRESS AT WELL LOCATION 1460 Highway 208 Yerington, NEV 89447

2. LOCATION SW ¼ SW ¼ Sec. 9 T. 11 N/S R. 25 E. Lyon County
PERMIT NO. None (Issued by Water Resources) 12-411-06 (Parcel No.) None (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	7	7
Large boulders + clay	✓	7	56	49
Sandy Clay some rock		56	75	19
Sand & Fine Solid Strata		75	98	23
Sandy Clay		98	125	27
Large sand + gravel	✓	125	154	29
Sandy Clay		154	160	6

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+	5 FT	2 HRS

Date started June 2, 1995
Date completed June 15, 1995

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
6 Inches		50 Feet	160 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	0	50
5 5/8		188	15	160

Perforations:
Type perforation Factory
Size perforation 3/32
From 50 feet to 80 feet
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 30 FT feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller (Contractor)
Address 170 Box 92 Smith Nev. 89430 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller (By driller performing actual drilling on site or contractor)
Date June 20 1995

JUN 22 AM 10:40 '95 STATE ENGINEER

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627