X

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49229
Permit No.
Basin 105

NOTICE OF INTENT NO. 26600

1. OWNER MIKE COFANO
MAILING ADDRESS GARDNERVILLE, NV
ADDRESS AT WELL LOCATION 1768 SOLITUDE GARDNERVILLE

2. LOCATION NE ¼ NE ¼ Sec. 2 T. 12 N/S R. 20 E. DOUGLAS County
PERMIT NO. — (Issued by Water Resources) 23-480-63 (Parcel No.) WILDFLOWER (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY W/GRAVEL		0	8	8
CEMENTED GRAVEL		8	29	21
SANDY CLAY W/GRAVEL		29	55	26
SANDY CLAY		55	59	4
SANDY CLAY W/GRAVEL		59	103	44
SANDY CLAY		103	124	21
SANDY CLAY W/GRAVEL		124	142	18
CLAY		142	146	4
SANDY CLAY W/GRAVEL		146	162	16
CLAY		162	179	17
SANDY CLAY		179	197	18
SANDY CLAY W/GRAVEL		197	222	25
SAND + GRAVEL	✓	222	240	18

'95 JUN 16 P1:00
STATE ENGINEERS OFFICE

Date started 5-23, 1995
Date completed 5-30, 1995

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	25+	—	1

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	50 Feet
9 7/8 Inches	50 Feet	240 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	240

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 3 X 3/32
From 220 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 240 feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDCO EXPLORATION, INC (Contractor)
Address 7780 CURRY RD (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
Signed Patl J. Moo[illegible] (By driller performing actual drilling on site or contractor)
Date 5-30-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627