

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 82070

1. OWNER CLARK CONST. ADDRESS AT WELL LOCATION 868 MARION GARDNERVILLE
 MAILING ADDRESS MINDEN, NV

2. LOCATION NW 1/4 SW 1/4 Sec. 17 T. 12 N. R. 20 E. DOUGLAS County
 PERMIT NO. 27-671-06 CHAMBERS FIELD Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sandy clay w/ cobbles</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>Course sand w/ gravel</u>		<u>5</u>	<u>18</u>	<u>13</u>
<u>Cobbles-gravel w/ some clay</u>		<u>18</u>	<u>56</u>	<u>38</u>
<u>Sandy clay w/ cobbles-gravel</u>		<u>56</u>	<u>61</u>	<u>5</u>
<u>Cobbles-gravel</u>		<u>61</u>	<u>97</u>	<u>36</u>
<u>Sandy clay w/ gravel</u>		<u>97</u>	<u>99</u>	<u>2</u>
<u>Large gravel w/ sandy clay & shales</u>	<input checked="" type="checkbox"/>	<u>99</u>	<u>140</u>	<u>41</u>

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 100 Feet
9 7/8 Inches 100 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>±2</u>	<u>140</u>

Perforations:
 Type perforation Factory Slotted
 Size perforation 3x3/2
 From 120 feet to 140 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 100 feet to 140 feet

9. WATER LEVEL
 Static water level 12.6" feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality good

Date started 8-15 1995
 Date completed 8-17 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>25+</u>	<u>—</u>	<u>1</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD. Contractor
FALLON, NV 89406

Nevada contractor's license number issued by the State Contractor's Board: 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1535

Signed Jerald W. Plimell
 By driller performing actual drilling on site or contractor
 Date 8-21-95

RECEIVED
 05 AUG 30 AM 10:27
 STATE ENGINEERS OFFICE