

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26573

1. OWNER MIKE COFANO ADDRESS AT WELL LOCATION 1819 SULLIVAN  
 MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE

2. LOCATION SW 1/4 NW 1/4 Sec. 24 T. 12 N. R. 20 E. DOUGLAS County  
 PERMIT NO. 29-490-02 RHEINSTROTH Subdivision Name  
 Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Sandy clay w/ cobbles &amp; gravel</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Cobbles &amp; gravel</u>		<u>3</u>	<u>17</u>	<u>14</u>
<u>Cobbles &amp; gravel w/ sandy clay</u>		<u>17</u>	<u>118</u>	<u>101</u>
<u>gravel w/ short clay streaks</u>		<u>118</u>	<u>188</u>	<u>70</u>
<u>Sandy clay some gravel</u>		<u>188</u>	<u>203</u>	<u>15</u>
<u>course sand</u>		<u>203</u>	<u>208</u>	<u>5</u>
<u>Sandy clay</u>		<u>208</u>	<u>212</u>	<u>4</u>
<u>course sand</u>		<u>212</u>	<u>217</u>	<u>5</u>
<u>Sandy clay course sand</u>		<u>217</u>	<u>260</u>	<u>43</u>

8. WELL CONSTRUCTION

Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>10 5/8</u> Inches	<u>0</u>	<u>50</u> Feet
<u>9 7/8</u> Inches	<u>50</u>	<u>260</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>+2</u>	<u>260</u>

Perforations:  
 Type perforation Factory slotted / T.C.  
 Size perforation 3 1/2  
 From Factory 160 feet to 180 feet  
 From T.C. 180 feet to 190 feet  
 From T.C. 200 feet to 215 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 260 feet

9. WATER LEVEL  
 Static water level 12.8 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDDCO EXPLORATION, INC Contractor  
 Address 7780 CURRY RD. Contractor  
FALLON, NV 89406  
 Nevada contractor's license number issued by the State Contractor's Board 27673  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535  
 Signed Jerald W. Phinney By driller performing actual drilling on site or contractor  
 Date 6-6-95

Date started 5-30, 1995  
 Date completed 6-6, 1995

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>20+</u>	<u>0</u>	<u>3</u>

JUN 16 P1:00  
 STATE ENGINEERS INC.