WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49234
Permit No.
Basin 05

NOTICE OF INTENT NO. 27114

1. OWNER Brad Dicks
MAILING ADDRESS P.O. Box 10245 South Lake Tahoe Cal. 96158
ADDRESS AT WELL LOCATION 1826 Cart Gardnerville Nev.

2. LOCATION NW ¼ SW ¼ Sec. 24 T. 12 N/S R. 20 E. Douglas County
PERMIT NO. ~~13777~~ Issued by Water Resources
29-502-14 Parcel No.
Rumstraw Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
rock & brown clay soil		0	55	55
Cobble stone some gravel	✓	55	78	23
clay & rock		78	120	32
gravel & Coarse sand	✓	120	160	40

'95 MAY -4 AM 11:13 RECEIVED STATE ENGINEER'S OFFICE

Date started April 26, 1995
Date completed May 2, 1995

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☑ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	5 ft	3 hrs.

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	60 Feet
6 Inches		60 Feet	160 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	0	160

Perforations:
Type perforation Factory saw slott
Size perforation 3/32 x 3
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 60
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☑ No
From — feet to — feet

9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller Contractor
Address P.O. Box 92 Smith Contractor
Nevada 89430
Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller By driller performing actual drilling on site or contractor
Date May 2, 95

USE ADDITIONAL SHEETS IF NECESSARY

Rev. 3-91 (O)-627