

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTEREST NO. 26599

1. OWNER LARRY SILVEIRA ADDRESS AT WELL LOCATION 1793 FISH SPRINGS
 MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE

2. LOCATION NE 1/4 NE 1/4 Sec 25 T. 12 N. R. 20 E DOUGLAS County
 PERMIT NO. _____ Parcel No. (new app) 1220-02-001-016 Subdivision Name WILDFLOWER

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MVD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	6	6
COMBINED GRAVEL/COBBLES		6	15	9
COMBINED GRAVEL		15	30	15
SANDY CLAY		30	38	8
CLAY		38	40	2
SANDY CLAY / GRAVEL		40	82	42
SAND / GRAVEL		82 91	91	9
SANDY CLAY / GRAVEL		91	100	29
SAND / GRAVEL		100	131	11
SANDY CLAY / GRAVEL		131	158	27
SANDY CLAY		158	172	14
CLAY		172	186	14
SANDY CLAY / GRAVEL		186	229	43
CLAY		229	232	3
SAND / GRAVEL	✓	232	235	2
SANDY CLAY / GRAVEL		235	255	20
CLAY		255	260	5
SAND / GRAVEL	✓	260	270	10

NE NE Sec 2 T12N
 R20E
 1793 Fish Springs Rd
 Old App 23-480-42
 NEW APP!
 1220-02-001-016

JUN 16 P1:00

8. WELL CONSTRUCTION

Depth Drilled 270 Feet Depth Cased 270 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>10 5/8</u> Inches	0	100
<u>9 7/8</u> Inches	100	270

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>11</u>	<u>270</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 x 3/32
 From 250 feet to 270 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 100

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 100 feet to 270 feet

Date started 5-31, 1995
 Date completed 6-5, 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25+</u>	<u>-</u>	<u>2</u>

9. WATER LEVEL

Static water level 90 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD Contractor
FALLON, NV 89406

Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726

Signed Pat A. Moore
 By driller performing actual drilling on site or contractor
 Date 6-5-95