X

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49237
Permit No.
Basin 105

NOTICE OF INTENT NO. 28023

1. OWNER Jerry Blades Construction
MAILING ADDRESS 1424 A Industrial Way Gardnerville NV. 89410
ADDRESS AT WELL LOCATION 1511 Salt Bush Gardnerville NV. 89410

2. LOCATION ~~NE~~ SE ¼ ~~SW~~ NW ¼ Sec. 36 T. ~~12~~ 13 N/S R. 20 E. Douglas County
PERMIT NO. Issued by Water Resources
Parcel No. 23-472-33 (now APN #1320-36-001-016) Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	2	2
Hardpack Clay		2	70	4
Course Sands and Gravels & Cobbles		70	180	110
Brown Gumbo Clay		180	225	45
Brown Sandy Clays w/Very Little Water	xx	225	330	105
Blackish Gray Clay		330	365	35
Gray Gumbo Clay		365	410	45
Small Sands and Gravels	xx	410	460	50

SE NW Sec 36 13N 20E
OLD APN
23-472-33
1511 Salt Bush Ct
New APN!
[redacted]

RECEIVED
SEP 18 PM 4:55
STATE ENGINEER'S OFFICE

Date started 9/12, 1995
Date completed 9/18, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	60	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 460 Feet Depth Cased 460 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
11 3/4	0	55
9 7/8	55	460

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	460

Perforations:
Type perforation Mill Slot
Size perforation 3 X 3/32
From 400 feet to 420 feet
From 440 feet to 460 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55 feet to 460 feet

9. WATER LEVEL
Static water level 260 feet below land surface
Artesian flow G.P.M. 30 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A-1 H Pump Company (Contractor)
Address 5550 Hwy 50 E #3 Carson City NV. 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack (By driller performing actual drilling on site or contractor)
Date 9-18-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627