

OFFICE USE ONLY
 Log No. 49240
 Permit No. _____
 Basin. _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28587

1. OWNER CIC INVESTMENT CORP ADDRESS AT WELL LOCATION: 94 SHARON DR
 MAILING ADDRESS: P.O. Box 11557 RENO, NV SMITH, NV

2. LOCATION SE 1/4 SE 1/4 Sec 29 T. 12 N. R. 23 E LYON County
 PERMIT NO. 09-021-03 FOOTHILL ESTATES Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders ^{1/2} sandy clay		0	30	30
DG ^{1/2} sandy clay		30	63	33
Blocker-pitavel ^{1/2} sandy clay		63	75	12
Boulders ^{1/2} sandy clay		75	99	24
Granite Outcrop ^{1/2} Fract		99	152	53
Sandy clay ^{1/2} DG		152	198	46
DG ^{1/2} some sandy clay	✓	198	205	7
Sandy clay ^{1/2} DG		205	218	13
Granite Outcrop ^{1/2} Fract	✓	218	252	34
DG ^{1/2} sandy clay	✓	252	260	8

8. WELL CONSTRUCTION
 Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)
 From To
15 Inches 0 Feet 260 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8.50</u>		<u>.188</u>	<u>±2</u>	<u>260</u>

Perforations:
 Type perforation Factory slotted / T.C.
 Size perforation 3x3/32
 From TC 198 feet to 205 feet
 From TC 220 feet to 240 feet
 From Factory 240 feet to 260 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 260 feet

9. WATER LEVEL
 Static water level 159 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD. Contractor
FALLON, NV 89406
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
 Signed Jerald W. Shinnell
 By driller performing actual drilling on site or contractor
 Date 8-15-95

Date started 6-29 1995
 Date completed 8-14 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>10</u>	<u>—</u>	<u>11</u>

RECEIVED
 95 AUG 30 AM 10:27
 STATE ENGINEERS OFFICE