WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49243
Permit No.
Basin 2 of 7

NOTICE OF INTENT NO. 22966

1. OWNER Harold Gibson Jr.
MAILING ADDRESS Po Box 15 Lund NV 89317
ADDRESS AT WELL LOCATION Portion of Lot 3 on East side of SR 318

2. LOCATION SW ¼ SW ¼ Sec. 21 T. 12 N/S R. 62 E. White Pine County
PERMIT NO. ~~13-082-14~~ N/A (Issued by Water Resources) | 13-082-14 (Parcel No.) | Lund ten acre plat (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	4	
clay gr conglomerate		4	8	
clay		8	20	
gravel		20	22	
clay		22	32	
gravel		32	34	
clay		34	42	
clay gravel con.		42	57	
gravel	water	57	64	
clay		64	69	
gravel	water	69	72	
clay		72	82	
gravel	water	82	85	
clay		85	90	
gravel	water	90	98	
clay		98	102	
gravel	water	102	113	
clay		113	118	
gravel		118	119	
clay		119	135	

'95 MAY 26 A11:40
RECEIVED
STATE ENGINEERS OFFICE

Date started April 5, 1995
Date completed May 18, 1995

7. WELL TEST DATA

TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40	5	1 hr.

8. WELL CONSTRUCTION
Depth Drilled 135 Feet Depth Cased 135 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	50 Feet
8 Inches	50 Feet	65 Feet
6 Inches	65 Feet	135 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	-1	135

Perforations:
Type perforation mill
Size perforation 1/8 x 2.5" x 6 row
From feet to feet
From 94 feet to 135 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 5-50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 65 feet

9. WATER LEVEL
Static water level 56 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Fair

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nathan R Maynard (Contractor)
Address Po Box 176 Lund NV 89317 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0022869
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
Signed Owen Maynard (By driller performing actual drilling on site or contractor)
Date May 23-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627